


14 65 STUD BOLT WITH HEAVY HEX. NUTS STUDS: 1/2 A 4
ASTM A193-B7, NUTS: ASTM A194-2H
FLUOROCARBON COATED WITH AMERI-COTE OR
APPROVED EQUAL

15	VALVE;BALL;RB;FLANGED;RF;150#; ;DATASHEET:A2R	2	A	1
16	Y-TYPE STRAINER 150# RF WITH 20mm DRAIN CONN. SP-ITEM SP-FS-001	2	A	1

17	PIPE STOP (NS50 TO 200) PS09-50-A-3	2	-	1
18	CANTILEVER(BOTH END WELDED) PS24-A-08	2	-	1

DESIGN PRESS: 167	kpag	DESIGN TEMP: 65/AMB	°C								
TEST PRESS: 2940	kpag	TEST WITH: Water									
RADIOGRAPHY: 100	%	STRESS RELIEVE: NO									
INSULATION SPEC: N/A											
COATING SPEC: DHF-00-M-S-0003											
				CO	29/05/09	HAZ	APPROVED FOR CONSTRUCTION	PSV/AH	TEM		
P&ID REF: WHP-DH2-R-D-1063				REV	DATE	BY	DESCRIPTION	CHECK'D	WP APPR'D	VSP	DATE



PDMS LINE NO.: CD-2"-DF-A-6301

Drawing No.:	SHEET NO.	REV.
DH2-P-D-6301-CD-2	2 OF 2	C0